

Hardness values for public water supplies in Co.Meath

Supply	CaCO3 (mg/l or PPM)	Clarkes or English dH	German dH	French dH
Abbeyfields, Clonard	342.75	24.0	19.2	34.3
Athboy	374.00	26.2	21.0	37.4
Ballinaclose	140.25	9.8	7.9	14.0
Ballivor	362.25	25.4	20.3	36.2
Carnaross	246.75	17.3	13.8	24.7
Castletown	329.88	23.1	18.5	33.0
Clonard	182.00	12.8	10.2	18.2
Clonee/Dunboyne	200.00	14.0	11.2	20.0
Drumcondrath	268.00	18.8	15.0	26.8
Dunsany	326.65	22.9	18.3	32.7
Dunshaughlin	314.88	22.1	17.6	31.5
East Meath (Stamullen)	321.00	22.5	18.0	32.1
East Meath (Duleek)	267.75	18.8	15.0	26.8
East Meath (Ashbourne)	306.25	21.5	17.2	30.6
East Meath (Ratoath)	236.25	16.6	13.2	23.6
East Meath (Bettystown/Laytown)	305.38	21.4	17.1	30.5
Enfield	236.00	16.6	13.2	23.6
Irishtown/The Ward	200.00	14.0	11.2	20.0
Jarretstown	200.00	14.0	11.2	20.0
Kells/Oldcastle (Kells/Carlanstown)	117.63	8.3	6.6	11.8
Kells/Oldcastle (Oldcastle/Crossakiel)	134.00	9.4	7.5	13.4
Kilmainhamwood	201.00	14.1	11.3	20.1
Kilmessan	349.50	24.5	19.6	35.0
Moynalty	388.00	27.2	21.7	38.8
Mulhussey	200.00	14.0	11.2	20.0
Lobinstown	271.25	19.0	15.2	27.1
Navan, Liscarton supply. Areas include; Town Centre, Kilberry, Oristown, Cortown, Boheermeen, Grieka, Dunderry, Robinstown, Balreask, Cannistown, Commons Rd, Ardsallagh, Ardmulchan.	223.19	15.7	12.5	22.3
Navan, Kilcarn supply. Areas include; Johnstown, Walterstown, Philpotstown, Decoy, Monkstown, Mooretown.	355.42	24.9	19.9	35.5
Nobber	385.25	27.0	21.6	38.5
Portmana	216.50	15.2	12.1	21.7
Slane	311.75	21.9	17.5	31.2
Trim	380.55	26.7	21.3	38.1