



- LEGEND:**
- LAP BOUNDARY
 - MV Overhead Three Phase Network
 - - - MV Overhead Single Phase Network
 - LV Overhead Three Phase Network
 - - - LV Overhead Single Phase Network
 - MRLV Underground Cable Information
 - HV Overhead Line Network
 - HV Underground Line Network
 - New Indicative Major Distribution Road
 - - - New Indicative Minor Distribution Road

12	2007	2007	SUBMIT FOR APPROVAL	OK	DT
11	2007	2007	LAP SECONDARY REVIEW	OK	DT
10	2007	2007	ESB FOR APPROVAL	OK	DT
Issue	Date	Discipline		By	Check

NOTE:
38kV Substation planned for Bettystown

Existing 38kV Substation

Site identification for 110kV Substation in IDA lands

Existing 110kV Overhead lines to be diverted underground along access routes to avoid development areas. Wayleave access over the cables will be required by ESB

Client:
MEATH COUNTY COUNCIL

Project:
LOCAL AREA PLAN DROGHEDA ENVIRONS

Title:
EXISTING ESB LAYOUT

Scale @ A1: **1:10,000**
 Prepared by: R.Krauskopf Checked by: G.Turley Date: November 2007
 Project Director: Ciaran O'Keefe

TOBIN
 Part of A. Tobin & Co. Ltd.
 Consulting, Civil and Structural Engineers,
 Block 15a, Grandmatteson Corporate Park,
 Dublin 15, Ireland.
 Tel: +353-01-4030439
 Fax: +353-01-4030439
 e-mail: info@tobin.ie
 www.tobin.ie

Drawing No: **Figure I.3** Issue: **C**